



R. V. BRIGGS & CO. PRIVATE LTD.

ANALYTICAL CONSULTING & TECHNICAL CHEMISTS

(AN ISO 9001:2015 & ISO 45001: 2018 CERTIFIED COMPANY)

TAHER MANSION, 1ST FLOOR

9, BENTINCK STREET, KOLKATA - 700 001

Phone : (033) 4044-3380/3381/3382 / 3383, Fax : 33 2248-0447

E-mail : rvbriggs.kolkata@gmail.com, Website : www.rvbriggs.com

CIN : U51109WB1931PTC007007



TC-7815

TEST REPORT

ULR NO. TC781522100007724F

No. W(D)/22-23/2755

Date : December 22, 2022

Page 1 of 2

Issued to : M/S. NABA DIGANTA WATER MANAGEMENT LIMITED
(A Joint Venture of Tata Steel Utilities & Infrastructure Services Ltd. & Voltas)
GN 11-19, Sector - V, Salt Lake, Kolkata - 700091

Your Ref. : 2022/NDWML/ARC/04 dtd. 13.06.2022

Sample Description : Drinking Water

Collection Source : Tap Water from Bennet Coleman Pvt. Ltd.,
EM- 2, Sec- V, Kolkata- 700091

Sample Drawn by us On : 15.12.2022 at 02:50 p.m.

Test Completed on : 16.12.2022

Parameters Tested:

Microbiological :

1) Coliform Organism (2) E.Coli

Method of Sampling : IS : 1622 : 1981

Environmental Condition : - Temperature: 26.5°C

Mode of Sampling : Grab

Sample Transport condition : Through Ice Box

Microbiological Test Findings :

Sl No.	Test parameters	Test Method	Unit	Result	Norms as per IS : 10500, 2012 (2nd Rev.), Amend. ,June 2015
1	Coliform Organism	APHA 23rd Edn. 9222 B	CFU/100ml	Absent	Absent
2	E. Coli	APHA 23rd Edn. 9222 H	CFU/100ml	Absent	Absent

Remarks on Test Report :

The above mentioned sample of drinking water complies with IS: 10500, 2012 (2nd Rev.) & Satisfactory for drinking purpose, in respect of the above mentioned parameters

: END OF TEST REPORT :

(Pijush Kanti Dutta)
Sr. Microbiologist
Authorized Signatory

ss



R. V. BRIGGS & CO. PRIVATE LTD.

ANALYTICAL CONSULTING & TECHNICAL CHEMISTS

(AN ISO 9001:2015 & ISO 45001: 2018 CERTIFIED COMPANY)

TAHER MANSION, 1ST FLOOR

9, BENTINCK STREET, KOLKATA - 700 001

Phone : (033) 4044-3380/3381/3382 / 3383, Fax : 33 2248-0447

E-mail : rvbriggs.kolkata@gmail.com, Website : www.rvbriggs.com

CIN : U51109WB1931PTC007007



TC-7815

TEST REPORT

ULR NO. TC781522100007724F

No. W(D)/22-23/2755

Date : December 22, 2022

Page 1 of 2

Issued to : **M/S. NABA DIGANTA WATER MANAGEMENT LIMITED**
(A Joint Venture of Tata Steel Utilities & Infrastructure Services Ltd. & Voltas)
GN- 11-19, Sector - V, Salt Lake, Kolkata - 700091
Your Ref. : 2022/NDWML/ARC/04 dtd. 13.06.2022
Sample Description : Drinking Water
Collection Source : Tap Water from Bennet Coleman Pvt. Ltd.,
EM- 2, Sec- V, Kolkata- 700091

Sample Drawn by us On : 15.12.2022 at 02:50 p.m.

Test Completed on : 16.12.2022

Parameters Tested:

Microbiological :

1) Coliform Organism (2) E.Coli

Method of Sampling : IS : 1622 : 1981

Environmental Condition : - Temperature: 26.5°C

Mode of Sampling : Grab

Sample Transport condition : Through Ice Box

Microbiological Test Findings :

Sl No.	Test parameters	Test Method	Unit	Result	Norms as per IS : 10500, 2012 (2nd Rev.), Amend. ,June 2015
1	Coliform Organism	APHA 23rd Edn. 9222 B	CFU/100ml	Absent	Absent
2	E. Coli	APHA 23rd Edn. 9222 H	CFU/100ml	Absent	Absent

Remarks on Test Report :

The above mentioned sample of drinking water complies with IS: 10500, 2012 (2nd Rev.) & Satisfactory for drinking purpose, in respect of the above mentioned parameters

: END OF TEST REPORT :

(Pijush Kanti Dutta)
Sr. Microbiologist
Authorized Signatory

ss

- ★ The test report shall not be reproduced, except in full, without written approval of the Company.
- ★ Results relate only to the parameters tested.